



**FIRE DEPARTMENT**  
9 METROTECH CENTER BROOKLYN, N.Y. 11201-3857

**CERTIFICATE OF APPROVAL # 5504**  
**THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE**

January 5, 2009

Mr. Glen Edgar  
VP - Research & Development  
Selkirk Corp.  
PO Box 63, 33828 Sutton Rd  
Logan, OH 43130

F.P. Index#: 0808006D

FPIMS#: 28140713

By order of Fire Commissioner Nicholas Scoppetta, and pursuant to FC112 of the New York City Fire Code, the following equipment or material is accepted for use provided the conditions as outlined below are in full compliance.

**Manufacturer:** Selkirk Corp.

**Product:** 2-hour fire rating UL listed factory-built grease duct system

**Model Number:** ZeroClear (IPS-Z3)

**Laboratory:** Underwriters Laboratories, Inc.

**Prescribed Tests:** UL 1978 and UL 2221

**Report:** File MH6673 Vol. 1 Sec. 1 Issued: 7-5-89 & Revised: 3-19-08  
File R21679 Project 04CA45896 issued August 11, 2004  
File R21679 Project 04CA45896 issued August 9, 2004  
YYGQ.MH11382 UL Online Certifications Directory

**Description:** Selkirk Model ZeroClear (IPS-Z3) is a listed factory-built grease duct system that is for venting grease laden vapors from commercial kitchen hoods. It incorporates its own 2-hour fire resistive enclosure and provides a zero/reduced clearance to combustibles and is rated for use at 500°F with intermittent operation at 2000°F.